



## Maintenance Schedule

This RO system was designed to ensure ease of use and low maintenance. If the filters are changed regularly as suggested below and is run within the suggested output capacity, the RO system should work properly for many years.

**Important!**

It is important to change the filters for stages 1, 2 and 3 at least every 6-12 months. The first 3 filters protect the RO membrane. If the filters are not changed, the membrane will be damaged and the RO system will be contaminated.

**Stage-1  
Sediment Filter**

**Replace every 6-12 Months**

If water source is from a private well or water source with high levels of heavy sediments; filter may need to be changed sooner.

**Stage-2 & Stage-3  
Carbon Filter**

**Replace every 6-12 Months**

If water source is from a private well or water source with high levels of heavy sediments; filter may need to be changed sooner.

**Stage-4  
RO Membrane**

**Replace every 2-3 Years**

Dependent on proper maintenance of stages 1-3 and level of water usage.

**Stage-5  
Post Carbon Filter**

**Replace every 2,500 Gallons (9,500 Liters)**

Usually replaced at the same time as the RO membrane.